

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0410:135 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Hochiki America, 7051 Village Dr., Suite 100, Buena Park, CA 90621-2268
Contact: *Bob Misiuk (714) 670-3251

DESIGN: Models SIH-24F and *SIJ-24 ionization type smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as ionization smoke detectors when used in conjunction with listed bases (CSFM Listing No. 7300-0410:132) and separately listed compatible fire alarm control units.

NOTE: Formerly 7256-0410:110 & 135

*Rev. 11-16--2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**